Outdoor unit Indoor unit	ARXS71L2V1B ADEQ71C2VEB							
- ·		ller a						
Function	Yes			Heating season	Yes			
Cooling Heating	Yes			Average (mandatory) Warmer (if designated)	No			
i i i i i i i i i i i i i i i i i i i			Colder (if designated)					
M	h	h /		   Inc		hr	h	
Item Design Load	Symbol	Value	Unit	Item Seasonal efficiency	Symbol	Value	Unit	
Cooling	Pdesignc	6.80	kW	Cooling	SEER	5,3	Į.	
heating / Average	Pdesignh	6.00	kW	heating / Average	SCOP / A	3.8	ļ.	
heating / Warmer	Pdesignh		kW	heating / Warmer	SCOP / W		-	
heating / Colder	Pdesignh		kW	heating / Colder	SCOP / C			
Declared capacity* for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio*, at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35°C	Pdc	6.80	kW	Tj = 35°C	EERd	2.67	-	
Tj = 30°C Tj = 25°C	Pdc Pdc	5.01 3.22	kW kW	Tj = 30°C  Tj = 25°C	EERd EERd	4.28 7.10	Ĺ	
Tj = 20°C	Pdc	1.54	kW	Tj = 20°C	EERd	7.24	-	
Declared capacity* for heating / Average season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Average season, at indoor temperature 20 °C and outdoor temperature Tj				
Ti = -7°C	Pdh	5.31	kW	Ti = -7°C	COPd	2.27	L	
Tj = 2°C	Pdh	3.23	kW	Tj = 2°C	COPd	3.91	ŀ	
Tj = 7°C	Pdh	2.08	kW	Tj = 7°C	COPd	5.01	ŀ	
Tj = 12°C Tj = bivalent temperature	Pdh Pdh	1.42 5.31	kW kW	Tj = 12°C  Tj = bivalent temperature	COPd COPd	5.03 2.27	t	
Tj = operating limit	Pdh	4.03	kW	Tj = operating limit	COPd	1.71	[.	
Declared capacity* for heating / Warmer season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Ti = 2°C	Pdh		kW	Ti = 2°C	COPd		-	
Tj = 7°C	Pdh		kW	Tj = 7°C	COPd		-	
Tj = 12°C	Pdh		kW	Tj = 12°C	COPd		-	
Tj = bivalent temperature Tj = operating limit	Pdh Pdh		kW kW	Tj = bivalent temperature  Tj = operating limit	COPd COPd		_	
i operating min	p 4							
Declared capacity* for heating / Colder season , at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance* / Colder season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = -7°C Tj = 2°C	Pdh Pdh		kW kW	Tj = -7°C  Tj = 2°C	COPd COPd		-	
Tj = 7°C	Pdh		kW	Tj = 7°C	COPd		[	
Tj = 12°C	Pdh		kW	Tj = 12°C	COPd		-	
Tj = bivalent temperature	Pdh Pdh		kW kW	Tj = bivalent temperature	COPd COPd		-	
Tj = operating limit Tj = -15°C	Pdh		kW	Tj = operating limit  Tj = -15°C	COPd		_	
			•	_				
Bivalent temperature	ть:	-7	l.c	Operating limit temperature	h-1	45	lec.	
heating / Average heating / Warmer	Tbiv Tbiv	-7	°C	heating / Average heating / Warmer	Tol Tol	-15	l°C °C	
heating / Colder	Tbiv		<u>°C</u>	heating / Colder	Tol		<u>°C</u>	
0			O. P. State of the Control of the Co					
Cycling interval capacity for cooling	Pcycc		kW	Cycling interval efficiency for cooling	EERcyc			
for heating	Pcych		kW	for heating	COPcyc		_	
Degradation co-efficient cooling**	Cdc	0.25	-	Degradation co-efficient cooling**	Cdh	0.25	-	
Electric power input in power models other th		Annual electricity consumption						
off mode	Poff	0.0125	kW	Cooling	QCE	449	kWh/a	
	OII	0.015=			~CE		1.300.7	
standby mode	<sup>P</sup> sb	0.0125	kW	heating / Average	QHE	2,210	kWh/a	
thermostat-off mode	PTO	0.002	kW	heating / Warmer	QHE		kWh/a	
crankcase heater mode	PCK	0.0	kW	heating / Colder	QHE		kWh/a	
		_						
Capacity control				Other items	1	l=0 / 0=	In (a)	
fixed	N			Sound power level (indoor/outdoor)	└WA	56 / 65	db(A)	
staged	N			Global warming potential	GWP	2,087.5	kgCO2eq.	
variable	<b>v</b>			Rated air flow (indoor/outdoor)		15.0 (0.000) /	3 <sub>/min</sub>	
variable				Rated air flow (indoor/outdoor)		56.5	m /min	
Contact details for obtaining more information	DAIKIN EUROPE I Zandvoordestraat B-8400 Oostende Belgium							
for staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'Declared EER/COP' of the unit.								
** if default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating of cooling cycling test value is required.								